


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

Township - Summers

BB1

1. Location of well:	County <b>Thomas</b>	Fraction <b>SE 1/4 NW 1/4 NW 1/4</b>	Section number <b>9</b>	Township number <b>T 9 S R 34</b>	Range number <b>4W</b>
2. Distance and direction from nearest town or city: <b>8 + 1/4 miles South: 33/4 Miles West</b> Street address of well location if in city:		3. Owner of well: <b>Joe McIlnay</b> R.R. or street: <b>RFD #2</b> City, state, zip code: <b>Colby, Kansas 67701</b>			
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E S 1 Mile</div> 		Sketch map:		6. Bore hole dia. <b>30</b> in. Completion date _____ Well depth <b>238</b> ft. <b>1/23/76</b>	
5. Type and color of material		From	To	7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored <input checked="" type="checkbox"/> Reverse rotary	
Clay & sand streaks		0	145	8. Use: _____ Domestic _____ Public supply _____ Industry <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other	
Fine to coarse sand & gravel		145	155	9. Casing: Material <b>Steel</b> Height: Above ground _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP _____ PVC _____ Weight <b>31.66</b> lbs./ft. Dia. <b>16</b> in. to <b>148</b> ft. depth Wall Thickness: _____ inches or Dia. _____ in. to _____ ft. depth gage No. <b>0.188</b>	
Sandy clay & cemented streaks		155	161	10. Screen: Manufacturer's name <b>Brown</b> <b>10" Cook</b>	
Fine to coarse sand & gravel		161	172	Type <b>Regular</b> Dia. <b>16"</b> Slot/gauze <b>10/4</b> Length <b>80'</b> Set between <b>148</b> ft. and <b>228</b> ft. <b>228</b> ft. and <b>238</b> ft.	
Sandy clay		172	178	Gravel pack? <input checked="" type="checkbox"/> Size range of material: <b>5/8:50</b> % #1	
Fine to coarse sand & gravel		178	191	11. Static water level: _____ mo./day/yr. <b>150</b> ft. below land surface Date <b>2/6/76</b>	
Sandy clay		191	201	12. Pumping level below land surfaces: <b>230</b> ft. after <b>2</b> hrs. pumping <b>1165</b> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <b>1165</b> g.p.m.	
Fine to coarse sand & gravel		201	218	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____	
Cemented sand		218	219	14. Well head completion: _____ Pitless adapter <b>12</b> Inches above grade	
Fine to coarse sand & gravel		219	235	15. Well grouted? <input checked="" type="checkbox"/> With: _____ Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay <input checked="" type="checkbox"/> Depth: From <b>0</b> ft. to <b>10</b> ft.	
<del>Cemented sandy clay shale</del>		235	238	16. Nearest source of possible contamination: ft. <b>3900</b> Direction <b>South</b> Type <b>Farm</b> Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No	
<del>Fine to coarse sand &amp; gravel</del>		238	266	17. Pump: _____ Not installed Manufacturer's name <b>Floway</b> <b>3-8-76</b> Model number <b>7610</b> HP <b>100</b> Volts _____ Length of drop pipe <b>220</b> ft. capacity _____ g.p.m. Type: <b>11 stage 10" DOH bow</b> _____ Submersible <input checked="" type="checkbox"/> Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other	
<b>Shale</b>		266	270	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Western Well and Pump 245</b> Business name _____ License No. _____ Address <b>PO Box 852 Colby, Ks.</b> Signed <b>Darryl Berry</b> Date <b>3/22/76</b> Authorized representative	
18. Elevation:		19. Remarks: <b>BROCK 235</b>			
Topography: _____ Hill _____ Slope <input checked="" type="checkbox"/> Upland _____ Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5