USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County Thomas	Fraction NW NW NW NV	<b>V</b>	Section r		Township number Range number 36
82 south of Brewster Street address of well location if in city:  R.R. or s			er of well: street: ate, zip c		Leoti Hanna Brewster, Kansas 67732
4. Locate with "X" in section below:					6. Bore hole dia. 8 in. Completion date Well depth 178 ft. 3-4-77  7 Cable tool
5. Type and color of material			From	То	10. Screen: Manufacturer's name
Top Soil® Sand and Sand Rock Strips			0 43	43 114	Type RMP Slot/gauze 1/3211 Set between 158 ft. and 178 ft.
Sandy Clay			114	146	Gravel pack? NES Size range of material 1/8 # ft.
Sand and Sand Rock Stri	. Ps	NECESSARIA PROSESSORIA SOCIA	146	158	11. Static water level: mo./day/yr. 160 ft. below land surface Date
Sandy Clay			158	160	12. Pumping level below land surfaces: ft. after NA_ hrs. pumping g.p.m.
Sand Fine			160	175	ft. after hrs. pumping g.p.m.
Shale	106		175	178	13. Water sample submitted: mo./day/yr.  Yes X No Date
					14. Well head completion:  10 Pitless adapter Inches above grade  15. Well grouted? Bentonite Concrete  Depth: From ft. to ft.  16. Nearest source of possible contamination:  ft Direction Type
		<del>a en en escado en ence</del>		<del>nggalay ng manda la basa Mada Nyad Billa</del>	Well disinfected upon completion? Yes No  17. Pump: Not installed  Manufacturer's name
					Model number HP Volts  Length of drop pipe ft. capacity g.p.m.  Type: Submersible Turbine  Jet Reciprocating
	sheet if needed)		<u> </u>		Centrifugal Other
18. Elevation:  Topography:  Hill  Slope  Upland  Valley	ndmill well.				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  Rantell Drilling 130 Business name License No. Address Winoma Kansas 67761 Signed Authorized representative