USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215 Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

						· -py / Nameda GOOLO
1. Location of well:	County Sherman	Fraction NH; NH; 1/4 1/4	SE S	ection 1	number	Township number Range number 9
				Owner of well: Vernelle Mann		
Streef address of well location if in city:    R.R. or street:   City, state, zip code:						rewster, Kansas 67732
4. Locate with "X" in section below:  Sketch map:						6. Bore hole dia. — 8 in. Completion date 10/5/77 Well depth — 110ft.
XW XE -				,		7 Cable tool X_ Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary
						8. Use: X Domestic Public supply Industry Irrigation Air conditioning Stock Lawn Oil field water Other
S						9. Casing: Materia PLSE   Height: Above or below  Threaded Welded S_L   Surface 15 in.  RMP X PVC Weight   lbs./ft.
5. Type and color of material				From	То	Diain. to ft. depth Wall Thickness: inches or Diain. to ft. depth gage No;
Top Soi	.1		- (	,	15	10. Screen: Manufacturer's name
<b>Sa</b> nd Hock				5	20	Slot/gauze 032 Length 20 \$ Set between 90 ft. and 110 ft.
Sand Hock and Sand Strips				20	25	ft. andft.  Gravel pack? YAS Size range of material1/5!!
sand Hock				<u>25</u>	37	11. Static water level: mo./day/yr.
sand and Sand Rock Strips				37	86	12. Pumping level below land surfaces:ft. after N • A • hrs. pumping g.p.m.
Sand and Clay Strips				56	94	ft. after hrs. pumping g.p.m.  Estimated maximum yield g.p.m.
Samd			9	14	104	13. Water sample submitted: mo./day/yr.
Uker	<b>5</b> 70 0 10	1041	1	04	110	Yes         X No         Date           14. Well head completion:         Z         Inches above grade
<del></del>	BKOOK	( 104'				15. Well grouted? Yes With: X Neat cement Bentonite Concrete
						Depth: From ft. to ft.
						16. Nearest source of possible contamination:  ft Direction Type  Well disinfected upon completion? Yes No
						17. Pump: Not installed
						Manufacturer's name <u>Red Jacket</u> Model number <u>1/1BC</u> HP 1 Volts 230  Length of drop pipe 100 ft. capacity g.p.m.
						Length of drop pipe ft. capacity g.p.m.  Type: XSubmersible Turbine
	(Use a second	sheet if needed)				JetReciprocatingOther
18. Elevation: 19. Remarks:						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report
Topography:						is true to the best of my knowledge and belief.  Bartell Drilling 139
X Hill Slope Upland						Business name  Address Winona Kansas 6 (64)
Valley						Signed Date Date Date Date Date Date Date Date