

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

AAB

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County SHERMAN	Fraction NW 1/4 NE 1/4 NE 1/4	Section number 3	Township number T 9	Range number S R 37 A/W
2. Distance and direction from nearest town or city: EDSON			3. Owner of well: VERNON ISAAC			
Street address of well location if in city: 4E 2E 1 1/4 E			R.R. or street: RT1			
4. Locate with "X" in section below:			City, state, zip code: Goodland Kansas 67735			
<p>Sketch map:</p>			6. Bore hole dia. 8 in. Completion date 9-10-79 Well depth 102 ft.			
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 60 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 4 in. to 62 ft. depth, Wall Thickness: inches or Dia. _____ in. to _____ ft. depth, gage No. _____			
5. Type and color of material			From	To	10. Screens: Manufacturer's name _____ Pitless	
Top Soil			0	4	Type Lower Dia. 5"	
Clay, Sand			4	36	Slot/gauze 1/8, 258 Length 30	
FINE SAND, M GRAVEL			36	71	Set between 62 ft. and 102 ft.	
M GRAVEL, SANDY CLAY			71	98	Gravel pack? YES Size range of material 1/8	
Ochre			98	102	11. Static water level: _____ mo./day/yr. 54 ft. below land surface Date 8-28-79	
					12. Pumping level below land surfaces: 90 ft. after 3 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade	
					15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.	
					16. Nearest source of possible contamination: NA ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: _____ Not installed Manufacturer's name Red Jacket Model number 98C HP 1/3 Volts 230 Length of drop pipe 100 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. S & H Drilling Co Inc 166 Business name _____ License No. _____ Address Goodland, KS Signed Bill Clifford Date 9-13-79 Authorized representative	
18. Elevation:	19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 9
 R 37
 W
 Sec 3
 NE 1/4 NE 1/4