

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CB13

1. Location of well:	County SHERMAN	Fraction NW 1/4 NW 1/4 SW 1/4	Section number 20	Township number T 9 S	Range number R 38 NW
2. Distance and direction from nearest town or city: Edson Street address of well location if in city: 2E 55			3. Owner of well: BILL SOMERS R.R. or street: RT 2 City, state, zip code: Goodland Kansas 67735		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: BINS HOUSE GRAVEL CLASSROOM 800' WELL		
5. Type and color of material			From	To	6. Bore hole dia. 8 in. Completion date _____ Well depth 163 ft. 9-1-79
TOP SOIL			0	4	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
CLAY SAND			4	48	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
M GRAVEL			48	59	9. Casing: Material PLASTIC Weight: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 60 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 4 in. to 127 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 1237
SANDY CLAY			59	70	10. Screen: Manufacturer's name _____ Peerless Type LOWVEE Dia. 5" Slot/gauze 1/8-258 Length 36' Set between 127 ft. and 163 ft. _____ ft. and _____ ft. Gravel pack? YES Size range of material 1/8
M GRAVEL SANDY CLAY			70	92	11. Static water level: _____ mo./day/yr. 112 ft. below land surface Date 7-13-79
M GRAVEL SANDSTONE			92	103	12. Pumping level below land surfaces: 140 ft. after 3 hrs. pumping 25 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.
CLAY			103	115	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
FINE SANDY M GRAVEL			115	121	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade
SANDY CLAY SANDSTONE			121	130	15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.
M GRAVEL SANDSTONE			130	158	16. Nearest source of possible contamination: ft. 800 Direction NW Type CESS POOL Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
COAL			158	163	17. Pump: _____ Not installed Manufacturer's name Red Jacket Model number 11CC HP 112 Volts 230 Length of drop pipe 150 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks: BROCK 158'				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. S.H. Drilling Co Inc 166 Business name _____ License No. _____ Address Goodland KS Bill Clifford Signed _____ Date 9-4-79 Authorized representative
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T
R
9
38
20
NW
SW
1/4
1/4
1/4