

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

to BWS
10-5-79
Q.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ottawa	Fraction NE 1/4 SW 1/4 NW 1/4	Section number 10	Township number T 9 S R 4	Range number 4
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: City Water Department R.R. or street: City Building City, state, zip code: Delphos, Kansas			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 36 in. Completion date 10-3-79 Well depth 64 ft. B.G.L.		
		<p style="text-align: center;">Well No. 7 (TH 1-79)</p>		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil		0	15	9. Casing: Material Steel Height: Above ground Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 30 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 45 lbs./ft. Dia. 12 in. to 49 ft. depth Wall Thickness: inches or Dia. 12 in. to 49 ft. depth gage No. 330		
Sandy brown clay		15	45	10. Screen: Manufacturer's name Layne & Bowler, Inc. Type Armco St. Dia. 12" Slot/gauze 105 Length 15' Set between 49 ft. and 64 ft. ft. and 64 ft. Grovel pack? yes Size range of material 1/8-1/4		
Med. gravel to coarse		45	50	11. Static water level: 33 ft. below land surface Date 8-15-79 mo./day/yr.		
Med. gravel to coarse-good color		50	55	12. Pumping level below land surfaces: 46 ft. after 4 hrs. pumping 250 g.p.m. 43 ft. after 4 hrs. pumping 200 g.p.m. Estimated maximum yield 300 g.p.m.		
Med. gravel to coarse-white		55	64	13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 8-29-79 mo./day/yr.		
Gray clay		65		14. Well head completion: <input type="checkbox"/> Pitless adapter 30 Inches above grade		
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.		
				16. Nearest source of possible contamination: ft. 600 Direction NE Type FARM Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name LAYNE Model number 91249L HP 20 Volts 230 Length of drop pipe 50 ft. capacity 250 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		WELL DEPTH MEASURED FROM GROUND LEVEL		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name License No. Address Wichita, Kansas Signed Dennis Appleby Date 10-4-79 Authorized representative		

T
R
S
Q
10
NE
SW
NW
SE
1/4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5