

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BCA

1. Location of well:		County SHERMAN	Fraction NE 1/4 SW 1/4 NW 1/4	Section number 31	Township number T 9 S R 40 E NW	Range number
2. Distance and direction from nearest town or city: Goodland Street address of well location if in city:			3. Owner of well: MAURICE TOWNSEND R.R. or street: R.F.D. 1 City, state, zip code: Goodland Kansas			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 26 in. Completion date 9-4-75 Well depth 299 ft.	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
M GRAVEL, SANDY CLAY, SANDSTONE		159	167	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 179 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219		
SANDY CLAY, SANDSTONE		167	175	10. Screen: Manufacturer's name W. H. BROWN Type LUGER Dia. 16 Slot/gauze 1/8 - 7 Length 120 Set between 179 ft. and 299 ft. ft. and <input type="checkbox"/> ft.		
M GRAVEL, SANDY CLAY, SANDSTONE		175	190	Gravel pack? Yes Size range of material 1/4 x 3/8		
M GRAVEL SANDSTONE		190	200	11. Static water level: _____ mo./day/yr. 162 ft. below land surface Date 9-6-75		
SANDY CLAY, ROCK		200	207	12. Pumping level below land surfaces: 270 ft. after 8 hrs. pumping 700 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 800 g.p.m.		
FINE SAND, SANDY CLAY, SANDSTONE		207	235	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
SANDY CLAY, SANDSTONE		235	242	14. Well head completion: _____ Pitless adapter _____ Inches above grade		
M GRAVEL, SANDY CLAY, SANDSTONE		242	257	15. Well grouted? Yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
SANDY CLAY, SANDSTONE		257	263	16. Nearest source of possible contamination: ft. _____ Direction NW Type _____ Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
FINE SAND, SANDY CLAY, SANDSTONE		263	282	17. Pump: _____ Not installed Manufacturer's name Western Land Raker Model number 8M HP 80 Volts Length of drop pipe 280 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
M GRAVEL, SANDY CLAY, SANDSTONE		282	296			
Shale		296	299			
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:			20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	3791 (TOPO)			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. W H Drilling Co Inc 166 Business name _____ License No. _____ Address Goodland Kansas Bill Puffer Signed _____ Date 9-23-75 Authorized Representative		

2
40
31
1/4 1/4 1/4