

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

BCB

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

SW NW NW

1. Location of well: County Shenman		Fraction 1/4 of 1/4	Section number 27	Township number T 9 S R 41	Range number 41
2. Distance and direction from nearest town or city: 6 miles So of Orlenton Street address of well location if in city:			3. Owner of well: Melvin Wilson R.R. or street: Rt 3 Box 66 City, state, zip code: Goodland Ks 67735		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 30 in. Completion date 4/16/76 Well depth 290 ft.	
5. Type and color of material top soil		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5' Porous Rock & clay, 5' sand & clay		110	120	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
6' Porous Rock, gravel and clay, 4' clay		120	130	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 32 lbs./ft. Dia 16 in. to 290 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>	
10' gravel, cemented gravel, strips of clay		130	140	10. Screen: Manufacturer's name W.A. Brown Enterprises Type Free Flow Dia. 16" Slot/gauze 3/16 Length 40' Set between 210 ft. and 290 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4	
5' gravel, 5' gravel & clay		140	150	11. Static water level: <input type="checkbox"/> mo./day/yr. 160 ft. below land surface Date 4-10-76	
10' gravel and clay mixed		150	160	12. Pumping level below land surfaces: 290 ft. after 3 hrs. pumping 1100 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1100 g.p.m.	
10' gravel		160	170	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>	
10' gravel		170	180	14. Well head completion: <input type="checkbox"/> Pitless adapter 12" inches above grade	
10' gravel & clay mixed		180	190	15. Well grouted? <input checked="" type="checkbox"/> Puddled clay With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
5' gravel, 5' gravel & clay		190	200	16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
2' gravel, 8' porous Rock & clay		200	210	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number 2370 HP 100 Volts 440 Length of drop pipe 280 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
10' Porous Rock and clay		210	220	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Jack Poore Drilling 1976 Business name McDonald Ks License No. <input type="checkbox"/> Address McDonald Ks Signed Jack Poore Date 4/76 Authorized representative	
8' Porous rock and clay 2' gravel		220	230	18. Elevation: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	
7' sand and gravel 3' rock		230	240	19. Remarks: 4' gravel - 6' shale 385Z (TUPO)	
5' clay, 5' porous Rock		240	250	Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	
1' clay 9' sand and gravel		250	260	Forward the white, blue and pink copies to the Department of Health and Environment	
10' gravel - 8' gravel 2' cemented gravel		260	280	Form WWC-5	
10' gravel - 8' gravel 2' cemented gravel		280	290	1/4 1/4 1/4 1/4	

1
 2
 4
 7
 27
 SW NW NW
 1/4 1/4 1/4 1/4