

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

411

| | |
|--|--|
| 1. Location of well: County SHERMAN Fraction SE 1/4 SE 1/4 NE 1/4 Section number 2 Township number T 9 Range number S R 41 E/W | |
| 2. Distance and direction from nearest town or city: SW 25 20 1/2 S 3. Owner of well: Billannon Street address of well location if in city: OF HOODLAND, KANS. R.R. or street: RT 2 City, state, zip code: HOODLAND, KANS. 67235 | |
| 4. Locate with "X" in section below: Sketch map: <div style="display: flex; justify-content: space-around;"> <div style="text-align: center;"> </div> <div style="text-align: center;"> </div> </div> | |
| 6. Bore hole dia. 10 in. Completion date 11-2-79 Well depth 274 ft. | |
| 7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary | |
| 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other | |
| 9. Casing: Material Steel Height: Above or below Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 16.75 lbs./ft. Dia. 4 1/2 in. to 274 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188 | |
| 10. Screen: Manufacturer's name DARRR Type Steel Dia. 4 1/2 Slot/gauze 1/2 Length 20 Set between 274 ft. and 294 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4X 1/2 | |
| 11. Static water level: <input type="checkbox"/> mo./day/yr. 164 ft. below land surface Date 9-20-79 | |
| 12. Pumping level below land surfaces: 210 ft. after 8 hrs. pumping 13 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 15 g.p.m. | |
| 13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/> | |
| 14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade | |
| 15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft. | |
| 16. Nearest source of possible contamination: ft. 1/4 Direction NE Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| 17. Pump: Not installed Manufacturer's name KOYLDS Model number 135M HP 2 Volts 230 Length of drop pipe 252 ft. capacity 13 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | |
| (Use a second sheet if needed) | |
| 18. Elevation: | 19. Remarks: 355 CONCRETE WAS RUN BY Farmer Billannon. |
| Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Foust Supply Co Inc 144 Business name License No. Address Box 338 HOODLAND, KANS 67235 Signed Ralph E. Foust Date 12-1-79 Authorized representative |

T 9
R 41
W
SE
SE
SE
SE