

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

TWP: Stateline

NDDB

1. Location of well:	County <b>Sherman</b>	Fraction <b>NE 1/4 SW 1/4 SE 1/4</b>	Section number <b>15</b>	Township number <b>T 9 S R 42 E/W</b>	Range number <b>42</b>
2. Distance and direction from nearest town or city: <b>From Kanorado &amp; I70 Interchange 3 1/2 miles South; 2 miles East</b>			3. Owner of well: <b>Jerry Winters</b>		
Street address of well location if in city: <b>1 MI. South; NW to well</b>			City, state, zip code: <b>Kanorado, Kansas</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>36</b> in. Completion date <b>5/21/76</b> Well depth <b>276</b> ft.	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material <b>Steel</b> Height: Above <b>XXXX</b> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>219</b> lbs./ft. Dia. <b>16</b> in. to <b>166</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. <b>7</b> guage	
5. Type and color of material		From	To	10. Screen: Manufacturer's name <b>Brown</b>	
<b>Clay</b>		<b>0</b>	<b>40</b>	Type <b>Regular</b> Dia. <b>16</b>	
<b>Sand and gravel and clay</b>		<b>40</b>	<b>96</b>	Slot <del>XXXX</del> <b>10%</b> Length <b>100'</b>	
<b>Clay</b>		<b>96</b>	<b>111</b>	Set between <b>166</b> ft. and <b>266</b> ft.	
<b>Coarse sand and gravel</b>		<b>111</b>	<b>137</b>	<b>10' Cook</b> <b>266</b> ft. and <b>276</b> ft.	
<b>Sandy clay</b>		<b>137</b>	<b>146</b>	Gravel pack? <b>yes</b> Size range of material <b>5/8 50%</b>	
<b>Coarse sand and gravel</b>		<b>146</b>	<b>154</b>	11. Static water level: <input type="checkbox"/> mo./day/yr. <b>130</b> ft. below land surface Date <b>5-13-76</b>	
<b>Clay</b>		<b>154</b>	<b>162</b>	12. Pumping level below land surfaces: <b>264</b> ft. after <b>2</b> hrs. pumping <b>556</b> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <b>556</b> g.p.m.	
<b>Coarse sand and gravel</b>		<b>162</b>	<b>168</b>	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.	
<b>Clay and layers of sand</b>		<b>168</b>	<b>184</b>	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> <b>12</b> inches above grade	
<b>Coarse sand and gravel</b>		<b>184</b>	<b>204</b>	15. Well grouted? <input checked="" type="checkbox"/> <b>Clay</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> <del>XXXX</del> Depth: From <b>0</b> ft. to <b>10</b> ft.	
<b>Fine medium sand</b>		<b>204</b>	<b>216</b>	16. Nearest source of possible contamination: ft. <b>1300</b> Direction <b>E/SE</b> Type <b>House</b>	
<b>Fine medium sand and clay</b>		<b>216</b>	<b>231</b>	Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
<b>Clay</b>		<b>231</b>	<b>238</b>	17. Pump: <input type="checkbox"/> Not installed	
<b>Coarse sand</b>		<b>238</b>	<b>260</b>	Manufacturer's name <b>Floway</b>	
<b>Coarse sand and some gravel</b>		<b>260</b>	<b>272</b>	Model number <b>7649</b> HP <b>100</b> Volts <input type="checkbox"/>	
<b>Shale</b>		<b>272</b>	<b>276</b>	Length of drop pipe <b>260</b> ft. capacity <b>500</b> g.p.m. Type: <b>11 stage 10" D.O.H. Bowl</b>	
				<input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine	
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	<b>3902</b>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Western Well &amp; Pump Inc. 245</b> Business name License No. Address <b>P.O. Box 852 Colby, KS.</b> Signed _____ Date _____ Authorized representative		