

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DIDA

1. Location of well: County <u>SHERMAN</u> Fraction <u>NE 1/4 SE 1/4 SE 1/4</u> Section number <u>16</u> Township number <u>T 9 S R 42 E 10</u> Range number	
2. Distance and direction from nearest town or city: <u>4.5 1/2 E 3/4 N</u> Street address of well location if in city: <u>C F KANDRADO</u> 3. Owner of well: <u>JAME LIVENSOOD</u> R.R. or street: City, state, zip code: <u>KANDRADO, KANSAS</u>	
4. Locate with "X" in section below: Sketch map:	
5. Type and color of material	
<u>Top Soil</u>	From <u>0</u> To <u>3</u>
<u>Clay Sandstone & Gravel</u>	<u>3</u> <u>133</u>
<u>Gravel</u>	<u>133</u> <u>136</u>
<u>Clay & Sandstone</u>	<u>136</u> <u>152</u>
<u>Gravel</u>	<u>152</u> <u>172</u>
<u>Sandstone & Clay</u>	<u>172</u> <u>198</u>
<u>Sand</u>	<u>198</u> <u>212</u>
<u>Sandstone Sand & Joint Clay</u>	<u>212</u> <u>254</u>
<u>Coarse Sand</u>	<u>254</u> <u>281</u>
<u>Soapstone</u>	<u>281</u> <u>283</u>
<u>Shale</u>	<u>283</u> <u>286</u>
<u>BROCK 281'</u>	
(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name <u>Trust Supply Co Inc 1414</u> License No <u>Boyl 338</u> Address <u>Woodland</u> Signed <u>Ralph Elman</u> Date <u>4-1-76</u> Authorized representative	

6. Bore hole dia. 16 in. Completion date 2-13-76
Well depth 283 ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material Steel Height: Above or below
Threaded Welded Surface 8 in.
RMP PVC Weight 37 lbs./ft.
Dia. 16 in. to 283 ft. depth Wall Thickness: inches or
Dia. in. to ft. depth Gage No. 188

10. Screen: Manufacturer's name WA. BROW
Type Mill self Dia. 16 "
Slot/gauze 1/8 Length 120'
Set between 160 1/2 ft. and 283 ft.
 ft. and ft.
Gravel pack? Size range of material 1/2

11. Static water level: 133 ft. below land surface Date 2-13-76 mo./day/yr.

12. Pumping level below land surfaces:
148 ft. after 8 hrs. pumping 500 g.p.m.
260 ft. after 16 hrs. pumping 700 g.p.m.
Estimated maximum yield 700 g.p.m.

13. Water sample submitted: mo./day/yr.
 Yes No Date

14. Well head completion:
 Pitless adapter inches above grade

15. Well grouted?
With: Neat cement Bentonite Concrete
Depth: From 10 ft. to ft. alone

16. Nearest source of possible contamination:
ft. Direction
Well disinfected upon completion? Yes No

17. Pump: Not installed
Manufacturer's name TAIT HXC
Model number 124CEL HP Volts
Length of drop pipe 270 ft. capacity 700 g.p.m.
Type: Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

-9
T
R
E
S
E
S
E
1/4 1/4 1/4 1/4