USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215

Mr. GIFULLER

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

CBA

Job #43-77-B-C-29-9-42

Fraction 1/4 NW 1/4 SW 1/4 County Section number Township number Range number 1. Location of well: Sherman 42 *@ 2. Distance and direction from nearest town or city: From Kanorado; 3. Owner of well: Ed Meissinger 6 South R.R. or street: Street address of well location if in city: Kanorado, Kansas City, state, zip code: 6. Bore hole dia. $\frac{36}{286}$ in . Completion date 7-19-74. Locate with "X" in section below: Sketch map: 7. __ Cable tool __ Rotary __ Driven _ ___ Hollow rod ___ Jetted ___ Bored XX Reverse rotary 8. Use: __ Domestic __ Public supply W __XIrrigation __ Air conditioning __ Stock XΙ ___ Lawn ___ Oil field water ___ 9. Casing: Material Steel Height: Above or Kekok Threaded ____ Welded ___ X_ Surface ____12 RMP______PVC _____Weight __.188_lbs./ft Dia. 16 in. to 176 ft. depth Wall Thickness: inches or – 1 Mile -Dia. ___ in. to ____ ft. depth gage No. . 5. Type and color of material From 10. Screen: Manufacturer's name <u>Brown</u> 0 Clay 46 Type <u>Regular</u> _ Dia.. Slot/gauze 10%100' Length Sand, Gravel, Clay, Cemented 46 76 Set between _ 10 John. 276 ft. and Gravel pack? X Size range of material 50% 1750%Clay 76 85 11. Static water level: 85 Sand, Gravel 96 135 ft. below land surface Date Clay 96 111 ft. after hrs. pumping Sand, Gravel 111 117 Estimated maximum yield -_g.p.m. Clay, Cemented 117 134 13. Water sample submitted: mo./day/yr X No Yes 134 Coarse Sand, Gravel 150 14. Well head completion: _ Pitless adapter Inches above grade Coarse Sand, Gravel, Clay Mix 150 202 15. Well grouted? X With: Neat cement X Bentonite X Concrete Sandy Clay, Sandstone Streaks 202 209 Depth: From 0 ft. to 10 ft. 16. Nearest source of possible contamination: ft. 3/4M Direction S=SE Type _ Clay 209 214 Farmstead 214 Fine Med. Sand 246 Well disinfected upon completion? ___ Not installed 246 251 Clay Manufacturer's name <u>Amari11o</u>

Model number <u>110784</u> HP <u>100</u> <u>Volts 480</u> Fine Med. Sand 251 279 Length of drop pipe 270 ft. capacity 900g.p.m. Type: 5 Stage 12 DOH Bow1 Fine Coarse Sand, Small Grave 279 284 ____ Submersible X Turbine ____ Jet __ Reciprocating Shale 284 286 _ Centrifugal Other 18. Elevation: 19. Remarks: 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Topography: WesternWell & Pump Hill Colby, KS Slope Authorized representative \underline{X} Upland Valley