

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

AAA

1. Location of well:		County SHERMAN	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 34	Township number T 9 S R 42 EW	Range number 42
2. Distance and direction from nearest town or city: KANORADO Street address of well location if in city: 75 HE				3. Owner of well: ART JOHNSON R.R. or street: City, state, zip code: KANORADO KS 67741		
4. Locate with "X" in section below: N NW --- NE --- W --- E --- SW --- SE --- S 1 Mile Sketch map: House Garage Cesspool slope → 400' WELL SHOP				6. Bore hole dia. 8 in. Completion date Well depth 278 ft. 8-22-79		
5. Type and color of material				From	To	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Top Soil				0	4	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Clay, FINE SAND				4	55	9. Casing: Material PLASTIC Height: Above below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 60" in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 4 in. to 2 1/2 X depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 237
M GRAVEL				55	64	10. Screen: manufacturer name PERKINS Type LOWER Dia. 5" Slot/gauze 1/8 X 258 Length 36 Set between 272 ft. and 278 ft. ft. and _____ ft. Gravel pack? YES Size range of material 1/8
SANDY CLAY, SANDSTONE				64	80	11. Static water level: _____ mo./day/yr. 144 ft. below land surface Date 8-15-79
M GRAVEL				80	93	12. Pumping level below land surfaces: 190 ft. after 3 hrs. pumping 15 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 g.p.m.
M GRAVEL, SANDSTONE				93	136	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
HARD SANDSTONE				136	138	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12" Inches above grade
M GRAVEL, SANDY CLAY				138	206	15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.
M GRAVEL				206	235	16. Nearest source of possible contamination CESS ft. 400 Direction NE Type POOL Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
SANDY CLAY				235	250	17. Pump: _____ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts 230 Length of drop pipe 188 ft. capacity _____ g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other
FINE SAND				250	256	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. St. A. Dullinger Co. Inc. 466 Business name _____ License No. _____ Address 2000 W. 12th St. Signed Bill Clifford Date 8-22-79 Authorized representative
FINE SAND, SANDY CLAY				256	265	
M GRAVEL				265	273	
Ochre				273	278	18. Elevation: 19. Remarks: Topography: ____ Hill ____ Slope ____ Upland ____ Valley (Use a second sheet if needed)
BROCK 273'						

T 9 S R 42 EW
Sec 34 NE 1/4 NE 1/4